

Preliminary Assessment Report

Project 3017175, 6000 16TH AVE SW

Assessment Completed: 3/24/2014

Project Description: Construct new approx. 59,000 sf, three story, classroom and lab building at South Seattle Community College. The building will contain general classrooms, Health Care Labs (Nursing), Computer labs and Faculty offices. This building is a replacement for Cascade Court (126) which will be demolished. Project follows the college 2007 MIMP.

Primary Applicant: [Andy Hartung](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Arthur Thomas Richardson, (206) 684-3655, art.richardson@seattle.gov

DPD Land Use Requirements

Christopher Amba Ndifon, (206) 233-7938, christopher.ndifon@seattle.gov

DPD Preapplication Site Visit Requirements

Roger E Moore, (206) 733-9039, Roger.Moore@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, yohannes.minas@seattle.gov

Seattle Public Utilities Requirements

Lan Chau

Water Availability

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

Existing Public Drainage Infrastructure

Sanitary sewer main location: 16th Ave SW

Sanitary sewer main size: 10-inch

Storm drainage main location: 16th Ave SW

Storm drainage main size: 12-inch

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Public storm drain system.

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Parcel-based projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure (bioretention cells, green roofs, permeable pavement, rainwater harvesting, etc.) to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible per SMC 22.805.020.F. and [Director's Rule 15-2012](#).

Flow control standards must be first met by utilizing green stormwater infrastructure to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using green stormwater infrastructure. Refer to [DR 17-2009](#). Submit a [Green Stormwater Requirement Calculator](#) along with additional flow control documentation.

For more information see: <http://www.seattle.gov/dpd/codesrules/codes/stormwater/default.htm>

This project site also discharges into a capacity-constrained system. In addition to meeting Pre-developed Forest or Pasture Standard, this project shall also comply with SMC 22.805.080.B4 (Peak Control Standard). The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre. Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre.

Projects with less than 10,000 sf new plus replaced impervious surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

This project site discharges to a Listed Creek Basin (SMC 805.050.A.2). Based upon the information provided on the Preliminary Application Form pertaining to land disturbing activity and existing and proposed impervious surfacing, this project shall provide flow control meeting the Pre-developed Pasture Standard per SMC 22.805.080.B.3. The post-development discharge peak flow rates and flow durations must be matched to the pre-developed pasture condition for the range of pre-developed discharge rates from 50% of the 2-year recurrence interval flow up to the 2-year recurrence interval flow.

Projects with less than 10,000 sf new plus replaced impervious surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

Water Quality

No requirements

Wastewater

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: Public storm drain system.

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

16TH AVE SW

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

Land Use

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

Based on the proposed use and location within a residential, multi-family, or commercial zone, an administrative conditional use permit may be required. See CAMs 211A and 211B for more details.

Based on the preliminary scope, the project may qualify for a specific exemption under the Environmentally Critical Areas Ordinance. Application and decision on the exemption must be made before submittal of a application. See CAM 327 for more details.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

- 1) Existing contours @ 2'-0 intervals.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Steep slope
Potential slide
Fish and wildlife

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Existing ROW Conditions

16TH AVE SW

Street conditions:

Asphalt paving

Visible pavement width is: Divided street

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 6 inches

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

Potential Impacts to Seattle Parks Property

Project abuts a park or park boulevard.

Park within 100 LF

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Inspectors Notes

1) Include earthwork calculations with submittal. Indicate total cut quantity and total fill/backfill quantity. 2) Some or all of the "Standard Submittal Requirements for Projects in an ECA" may be omitted or modified by DPD Geotechnical Engineers once specific location for this building is determined.

Standard Submittal Requirements for Projects in an ECA

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per [SMC 22.170.070](#), [SMC 25.09](#), and [Directors Rule \(DR\) 18-2011](#).

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see [25.09.330A](#))

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Site is mapped as being within a fish and wildlife habitat area. The characteristics of the fish and wildlife habitat area will be used to evaluate development within wetlands, riparian corridors, steep slopes, and designated habitat areas

Seattle City Light Requirements

Street/Alley Requirements

16TH AVE SW

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10/NDK-50, Electrical Conduit and Facilities in the Public Rights of Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center

("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). The existing service to the site is underground from 16th Ave SW.

Other requirements: The new construction appears to be over or near underground high voltage lines. Before digging contact the Utilities Underground Location Center ("One-Call") at 1-800-424-5555 two business days in advance to locate and mark underground utilities, per State law (RCW 19.122).

Relocate existing electric service wire, equipment, and/or meter at project's expense. Relocation may be needed based on utility locates and building location.

Other requirements: Power for the new building must come from the existing electrical service to the site per SCL's "one site-one service" rule. For clarification and advice, please contact your Electrical Service Engineer.

Notes to Applicant

To ensure that the existing service at the site can accommodate the new construction, please provide new electrical load information to Seattle City Light. Contact your Electrical Service Engineer well in advance for SCL-related electrical advice or consultation. Your Electrical Service Engineer is: Ken Houlder, 206-233-0045, ken.houlder@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SPU Requirements

Water Availability

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20140444

Water Availability Certificate status: Approved with No Changes

Prepared by: Richard F Wilson

Existing Water System Information

Proximity of nearest fire hydrant is: 400 feet W of property. Meets standards.

Water Main:

Size: 12 inches Material: Cast Iron Class: 22

- Standard

- Abutting

Water Main is available to serve in: 16th Avenue SW

Distance of main to E margin of street is 40 feet.

Public ROW width is 80 feet.

Water Service(s):

Size: 8" Material: Ductile Iron

Size: 8" Material: Ductile Iron

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seattle.gov.

Other Requirements

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).